## Village of Payne CSO Annual Report

(May 1, 2022– May 1, 2023)

- CSO Locations:
  - 1.) 002 State Route 500 Inlet 40" Overflow 40" with 2 swing checks
  - 2.) 003 is now located at the retention pond.
  - 3.) Fox Street Inlet 10" overflow 8" This no longer exists; it was capped in 1999. (This was previously coded as 003)
- A CSO Overflow Event at 003 (the retention pond) during A Multiple Day High Rain Event leading up to January 21<sup>st</sup> 2023, which a noticeable discharge was approximately 150,000 Gallons over a 3 day period out of the retention pond off of State Route 500 into the Flat Rock Creek.
- A CSO Overflow Event at 003 (retention pond) during multiple high rain event days leading up to February 23<sup>rd</sup> 2023. A noticeable discharge was approximately 200,000 gallons over a 5 day period out of the retention pond off of State Route 500 into the Flat Rock creek.
- Permittee Contact information can also be found at Payne village hall located at (119 N. Main St. Payne, OH 45880 Phone: 419-263-2514 ext 6
- The Village has put in and maintained a retention pond located off State Route 500. The Village and EPA hopes to limit overflows to one or less a year depending on precipitation.
- If any discharge is seen please contact Brant Heck, Payne Water/sewer operator, 419-263-2514 ext 6 Email: <u>Waterdept@villageofpayne.com</u>, Or John Hall, BPA President, 419-399-7530 Email: <u>bjhall42@yahoo.com</u>
- Minimum control:
  - The village provides proper operation and maintenance for the cso and sewer system
  - The village uses the storage system during wet weather to its maximum capacity before allowing an overflow
  - The village reviews and modifies local programs to minimize impact nondomestic discharges from combined sewer overflows
  - The village maximizes the capabilities of the POTW to treat wet weather flows and maximize wet weather flow to wastewater plant within the limits of the plant
  - The village prohibits dry weather overflows
  - The village controls solid floatable materials in combined sewer overflow
  - The village does the required inspection, monitoring and reporting of CSO
  - The village does pollution prevention programs that focus on reducing the level of contaminants in cso
  - The village implements a public notification programs of areas affected by CSO through a website and posted signs